

Gate three query process

Strategic solution(s)	London Water Recycling (LWR)
Query number	LWR010
Date sent to company	23/01/2025
Response due by	27/01/2025

Query

Can you confirm that the scheme will not operate during high tide events that overtop Teddington weir?

Solution owner response

This response has been written in line with the requirements of the RAPID Gate 3 Guidance and to comply with the regulatory process pursuant to Thames Water's statutory duties. The information presented relates to material or data which is still in the course of completion. Should the solution presented be taken forward, Thames Water will be subject to the statutory duties pursuant to the necessary consenting process, including environmental assessment and consultation as required. This response should be read with those duties in mind.

R1: We confirm that the Teddington DRA scheme design will incorporate controls to prevent abstraction of river water and discharge of recycled water during tidal overtopping of Teddington Weir.

These controls will prevent any saline water entering into the Thames Lee Tunnel.

If you require any further information, please contact the strategic solution contact below.

Date of response to RAPID	27/01/2025
----------------------------------	------------